



88 Empire Drive • St. Paul, Minnesota • 55103
 (651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

November 25, 2009

Supplier: Hilti Entwicklungsgesellschaft mbH
 BU Chemicals
 Hiltistrasse 6
 86916 Kaufering
 GERMANY

Sample Description: Hilti CF-812

Date tested: October 1, 2009

Test Method: SCAQMD method 304-91 Determination of Volatile Organic Compounds (VOC) in various materials as referenced by South Coast Air Quality Management District (SCAQMD) rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data: Legend Project Number 0903311

Specification	Product
LEED 2009 (LEED 3.0) LEED 2.2 IEQ-4.1: Low-Emitting Materials – Architectural Sealant	Hilti CF 812
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
Architectural Sealant; VOC Limit: 250 g/L	Product contains: 2.4 g/L of VOC

William Welbes
 Vice President of Laboratory Operations

Allen Noreen, Ph.D.
 Technical Director