Plastic pipes Through Slab

APPLICATION:

CP638: MP-RF-M-01

INFORMATION:

- Not to scale
- All units are in millimetres
- Tested according EN 1366-3
- Classification Report 23003B

CP 638 Mortar + CFS-C EL

ID:


DATE:


01

11/2024

Fire Rating El 120

Page 1/1





Spacing overview for mixed seals					
Description	Shortcut	Distance			
To seal edge	b	≥ 50 mm			
To other pipes with CFS-C EL	C ₁	≥ 38 mm			
To cables with CFS-IS	c ₂	≥ 38 mm			
To any other services	C ₃	≥ 100 mm			

PE pipes in acc. EN 1519-1, EN 12201-1, EN 15494, EN 12666-1, PE-X pipes in acc. EN 15875-2, ABS pipes in acc. EN 1455-1 and EN 15493, as well as SAN+PVC in acc. ISO 19220.

Number	Hooks	Diameter	Wall	Fire rating in mixed
of layers			thickness	opening
1	3	≤ 75 to 90 to 110 mm	3 to 3.7 to 4.2	EI 120-U/U
2	4	≥ 125 to 160 mm	4.9 to 6.2 to 9.5	EI 120-U/U

PVC pipes in acc. EN 1329-1, EN 1453-1, EN 15493, EN 1452-2.

Number of layers	Hooks	Diameter	Wall thickness	Fire rating in mixed opening
1	3	≤ 40 to 110 mm	1.9 to 2.7 to 6.6	EI 120-U/U
2	4	≤ 160 mm	6.2 to 9.5	EI 120-U/U

Maximum opening size without additional support: 2000 x 1800 mm or reduced width, with up-to 10m length. See classification report for further details.

Hilti (Gt. Britain) Limited | No 1, Circle Square | 3 Symphony Park | Manchester | M1 7FS

Freephone: 0800 886 100 | Website: www.hilti.co.uk

^{1.} The application limits on this detail are for guidance purposes only. For more detailed information based on the full range of available test results please contact the Hilti Technical Advisory Service.

2. The product and application has been assessed as a minimum to the BS 476 standard. It may have additional European and worldwide testing. Please contact Hilti for further information.

3. All installations should be carried out in accordance with Hilti's installation instructions and by competent & experienced installers using Hilti branded products.

4. All services are to be correctly and adequately supported to prevent collapse and distortion.