

# DECLARATION OF PERFORMANCE

according to Annex III of the Regulation (EU) Nr. 305/2011 (Construction Products Regulation)

## Hilti Firestop Collar CFS-C P

No. Hilti CFS-C P

**1. Unique identification code of the product-type:**

Hilti Firestop Collar CFS-C P

**2. Intended use:**

Fire Stopping and Sealing Product for Penetration Seals, see ETA-10/0404 (30.4.2015)

Pipe penetrations	Plastic pipes Composite pipes
-------------------	----------------------------------

**3. Manufacturer:**

Hilti Corporation, Feldkircherstrasse 100, 9494 Schaan, Principality of Liechtenstein

**4. System of ACVP:**

System 1

**5. European Assessment Document:**

of ETAG No. 026-1 and ETAG No. 026-2

**European Technical Assessment:**

ETA-10/0404 (30.04.2015)

**Technical Assessment Body:**

OIB Austrian Institute of Construction Engineering

**Notified body/s:**

MPA Braunschweig, No. 0761

**6. Declared performance:**

Essential characteristic	Declared performance	Harmonised technical specification / Method of verification
Reaction to fire	Class E	EN 13501-1
Resistance to fire	see ETA-10/0404 (30.4.2015)	EN 13501-2
Air permeability		Tested according to EN 1026
Water permeability		Tested according to ETAG 026-2
Content, emission and/or release of dangerous substances		
Protection against noise		EN ISO 140-3, EN ISO 717-1 and EN ISO 20140-10
Durability and serviceability		Z <sub>2</sub>
Other		No performance assessed

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above. Signed for and on behalf of the manufacturer by:

**Dorothy Wai**  
Product Manager  
Business Unit Chemicals  
Hilti Corporation

**Martin Althof**  
Head of Quality  
Business Unit Chemicals  
Hilti Corporation